

(M) Persons/hour Using Rest Room During Design Hours(1)	Number of Facilities – Men’s Room (2)			
	Urinals (3)	Toilets (3)	Wash Basins (3)	Hand Air Dryers (3)
0-105	2	2	2	2
106-225	4	4	4	4
226-315	6	6	6	6
316-375	8	6	6	6
376-435	10	6	8	8
436-500	12	8	10	10
(W) Persons/Hour Using Rest Room During Design Hours(1)	Number of Facilities – Women’s Room (2)			
	Toilets (3)	Wash Basins (3)	Hand Air Dryers (3)	
0-105	6	4	4	
106-225	10	6	6	
226-315	14	8	8	
316-375	18	10	10	
376-435	20	12	12	
436-500	24	14	14	

Notes:

1. See [Figure 51-2A](#) to determine the number of persons/hours.
2. Dual men/women facilities (minimum of 2 each) should be provided. The number of fixtures should be divided equally among the rest rooms.
3. At least one fixture should be handicapped accessible in each rest room provided. For additional criteria, see ADA Guidelines.

GUIDELINES FOR COMFORT FACILITIES

Figure 51-2C